

B1-6RTD Right Side 6 Channel RTD Temperature Input Module

Introduction

B1-6RTD is one of the temperature input modules of FATEK B1 series PLC. It provides 6 channels of RTD temperature measurement input with $0.1~^{\circ}\text{C}$ or $1~^{\circ}\text{C}$ resolution. The scan rate for $0.1~^{\circ}\text{C}$ resolution is 2 seconds, while the scan rate for $1~^{\circ}\text{C}$ resolution is 1 second. This module provides three-wire connection for RTD temperature sensor, thus can automatically compensate the resistance introduced by the wiring. All the optional features of this module are software configurable, there are no hardware jumpers or switches for user to setup.

Dimension






Specifications

| Specifications | |
|-----------------------------------|--|
| Expansion Type | Right Side |
| Total Channels | 6 CH |
| Resolution | 0.1°C or 1°C |
| I/O Points Occupied | 1 RI(Input Register) and 8 DO - B1 PLC support up to 64 IR |
| Conversion Time | 1 or 2 Seconds |
| Accuracy | ±1 % |
| Sensor Type | Pt-100, Pt-1000 (JIS or DIN) |
| Software Filter | Moving Average |
| Average Samples | 1, 2, 4, 8, 16 Samples |
| Measurement Range | Pt-100: -200 ~ 850°C |
| | Pt-1000: -200 ~ 600°C |
| Isolation | Transformer (Power) and Photo-couple (Signal) |
| Indicator(s) | 5V PWR LED |
| Supply Power | 24V-15%/+20%, 2VA |
| Internal Power Consumption | 5V, 35mA |
| Operating Temperature | 0 ~ 60 ℃ |
| Storage Temperature | -20 ~ 80 °C |


| Case Type Support | Standard Case |
|-------------------|----------------------|
| Dimensions | 35(W)x90(H)x60(D) mm |

Wiring Diagram



I/O Configuration

Before the temperature value can be retrieved, the user should perform the I/O configuration of temperature module with the help of Winproladder software. The following screen will be shown when perform the I/O configuration.



The user need to assign a starting register of a contiguous register area for holding temperature reading value and areas for storing the configuration table and working scratchpad and define the sensor type, unit of temperature, scan speed and samples for average.