



*EasyAccess*2.0

EasyAccess 2.0 Startup Guide

Remotely monitor and control your HMI





Table of Contents

1. Overview	1
2. Features	1
3. System Requirement and Installation	1
System Requirement	1
Installation	2
4. Getting Started.....	5
Understanding EasyAccess 2.0	5
Understanding Domain, HMI Group, and User	6
Setup Checklist	8
5. Activate an HMI	9
With an Activation Card	10
With an Activation Card on PC Activator	11
By Hardware key through dealer	11
6. Add an HMI to a Domain	12
7. Manage the Domain	14
Domain Creation	14
User Management	14
Device Management	16
8. Configure EasyBuilder Pro Project	19
EasyBuilder Pro System Tags	19
9. Connect the HMI to EasyAccess 2.0 Servers	21
10. EasyAccess 2.0 PC client Program	22
Installing adaptors	22
Log in	22
Main screen.....	22
Settings.....	23
HMI States and Access Setting	24
Connection Log	26
Usage Display	27
11. Connect to the HMI by EasyAccess 2.0 on PC.....	28
12. Pass-through with EasyAccess 2.0	29
13. Pass-through Connect to a remote PLC on the HMI's network (Ethernet pass-through)	30
14. Proxy Server	32



Proxy related system tags	33
15. EasyAccess 2.0 on Android.....	34
App Download.....	34
Step-by-step connection guide	34
16. EasyAccess 2.0 on iPad.....	36
Download from the app store.....	36
Step-by-step connection guide	36
17. Frequently Asked Questions	39
18. References	41
System Restrictions	41
Model and OS Support.....	41
19. Appendix.....	43
Terminology.....	43
Example for preparing EasyAccess 2.0 page	43

1. Overview

Traditionally, accessing a remote HMI is a convoluted job. Security concerns and tricky network parameters setup makes it difficult for many HMI users. And even with proper setup, access is still quite limited, allowing connection to only one HMI within the remote network. However, with EasyAccess 2.0, this has all changed.

EasyAccess 2.0 provides a new way for accessing an HMI from anywhere in the world. With EasyAccess 2.0, it becomes very easy to monitor and troubleshoot HMI and PLC that are at a remote location as long as Internet connection is available. As EasyAccess 2.0 already takes care of network settings and addresses security issues, the user can connect easily to the HMIs as if they were on the local network. Moreover, it is possible to have access multiple HMIs within a network.

EasyAccess is also a remote supporting service. Consider the case in which a machine builder has sold his machine with a Weintek HMI installed, and one of his oversea customers is reporting a problem, which may or may not require inspection by an engineer. He can remotely connect to the HMI through EasyAccess 2.0 to investigate the problem. The customer needs no extra network configuration, just Internet connection. In addition, he can also update the HMI project, monitor the PLC by Ethernet Pass-through, or even update the PLC program.

2. Features

- Secure connections
- Little PC setup required; no router setup required
- User friendly administrator and client UI
- Supports pass-through and proxy server

3. System Requirement and Installation


System Requirement

- PC Operation System: Windows XP, Windows 7, Windows 8 (32 / 64bit)
(Require Administrator privilege)
- Weintek HMI with EasyAccess 2.0 feature activated ([Eligible HMI models](#))
- Internet Connection
- EasyBuilder Pro V4.10.05 or later


- iPad: iOS 7.0 or above
- Android: V4.1.2 or above

Installation


1. Download the setup.exe file from EasyAccess 2.0 homepage and open it. Select the language for the installation process, and then click [Next]. If there is a previous version of EasyAccess 2.0 on the PC, please remove it before installation .




2. Select a folder for EasyAccess 2.0 installation, or use the default folder. Click [Next].




3. Select a start menu folder, or use the default folder. Click [Next].




4. Select additional tasks, for example: [Create a desktop icon]. Click [Next].



5. Confirm all setting. To change the setting, click [Back]. To start installation, click [Install].



6. Installation progress.



7. Click [Finish] to complete the installation.



Here is a list of notable files in the installation folder:


File Name	Description
cMT Viewer	The PC application for accessing a cMT-SVR.
EasyAccess 2.0	The main program used to establish remote connection to an HMI.
gui_30	An essential component when using HMI Viewer to monitor a remote HMI.
PC Activator	Application for activating EasyAccess 2.0 for HMI on the network.
EA_V2xxxx_ReleaseNotes (pdf)	Release notes documenting important changes of EasyAccess 2.0 to date.

4. Getting Started

Understanding EasyAccess 2.0

EasyAccess 2.0 access technology is quite different from traditional way of remote access method. Here are some notable points:

<i>Traditional remote connection (blue links)</i>	<i>EasyAccess 2.0 (green dotted links)</i>
<ul style="list-style-type: none"> Connection traffic must pass through a number of firewalls, which means there are layers of network settings. 	<ul style="list-style-type: none"> PC and HMI both connect to a dedicated VPN server, through which data are exchanged.
<ul style="list-style-type: none"> Network/Router setting is mandatory; therefore, coordination with the IT department is crucial. 	<ul style="list-style-type: none"> No additional network setting is required.
<ul style="list-style-type: none"> For one WAN IP, only one device can be connected. 	<ul style="list-style-type: none"> For one WAN IP, multiple devices can be connected.
<ul style="list-style-type: none"> For a device behind two or more routers, connection might not be possible. 	<ul style="list-style-type: none"> Being behind several routers does not affect EasyAccess 2.0 connectivity at all.



EasyAccess 2.0 Network Overview

Understanding Domain, HMI Group, and User

The basic management block is Domain, under which HMIs, HMI Groups, and Domain Users exist. An HMI, upon activation, can be added to a domain.

Activation: The first step towards using EasyAccess 2.0. Each HMI has its EasyAccess 2.0 feature disabled by default, and must be activated in order to use the feature. A purchased license can be used to activate any one of the supported models; however, once an HMI has been activated, its license cannot be transferred to another HMI.

Domain and Domain Admin: The basic block of HMI management. One Domain account may contain a number of Users, HMIs and HMI groups. However, each HMI can belong to only one Domain. The Domain Administrator manages all aspects the domain through the web-based portal at (<https://account.ihmi.net>). Note that domain account is *not* used for logging in the EasyAccess 2.0 client program.

HMI Group: A subset of HMIs within a domain. A user in an HMI Group can access all HMI in that group. For the Domain Admin, HMI Groups provide an easy way for management of user access to HMI. An HMI can belong to more than one HMI groups.

User: A user holds the account used to login in to the EasyAccess 2.0 program. They are allowed access to HMIs for which it has direct association, and also HMIs within the group it is associated with. User's relationship with HMIs and HMI Groups are managed by the Domain Admin.

The prime principle governing HMI management in EasyAccess 2.0:


An HMI can belong to one domain only at any given time

Example

Consider the following figure for an illustrative example of a domain.

- In this example, the domain, named “MyDomain” has two users, Peter and Nina.
- In this example, HMI are grouped together as Group I, Group II, Group III...etc, and one HMI belong to more than one groups. (HMI A)
- Users can belong to many groups, and have access to the HMI in the groups they belong to. (User Peter & Group I)
- Users can be directly associated with HMI and have access to them. (User Nina & HMI J)
- Multiple users can access the same HMI, whether by assignment to groups (HMI A) or by direct association (HMI H).

All of this is done by the Domain Admin. The Domain Admin can exercise large amount of freedom in domain management.



A sample domain "MyDomain"

Setup Checklist



Please review the following checklist to start using EasyAccess 2.0. See relevant sections describing the functions in detail.

Check	Relevant Section
✓ The HMI must be activated.	(5. Activate an HMI)
✓ The HMI must be registered in a Domain.	(6. Add an HMI to a Domain) (7. Manage the Domain)
✓ The HMI must be programmed to go online.	(8. Configure EasyBuilder Pro Project) (9. Connect the HMI to EasyAccess 2.0)
✓ The user must have a user account which is associated with an HMI.	(7. Manage the Domain)
✓ EasyAccess 2.0 must be installed.	(10. EasyAccess 2.0 PC client Program)

Having all set up, the user may then initiate remote connection to the HMI!

[\(11. Connect to the HMI by EasyAccess 2.0\)](#)


5. Activate an HMI

The HMI must have been activated in order to be connected using EasyAccess 2.0. Check its activation status on HMI in the [EasyAccess 2] tab of the [System settings] page.

Your HMI may have been activated already. If not, an HMI can be activated by one of the following means:

- Self-serve activation with activation codes on Domain web page
- Self-serve activation with activation codes on PC Activator
- Activation by Weintek's authorized dealer

In either case, HMI's Hardware key will be required. Locate it in the [EasyAccess 2] tab of system setting.



Activation status and Hardware key

With an Activation Card

If you have an activation card, you may activate the HMI with the Activation codes printed on the card through the domain management system.



Activation Card

1. Visit <https://account.ihmi.net> login to your Domain with your credential.
2. In [Devices] tab » [Add HMI], enter the Hardware key and your Activation code

Note: Activation by activation card will also add the HMI to the domain.

+ Add HMI Weintek_FAE

Action type Using activation card

Hardware key * X3POSPSS-YZfZ-PJc3-QOED-HFP7-3GSN5IB

Activation code * 1234 - 4568 - 5563 - 2232 ✔

Custom Field1 Test

Custom Field2 Activation

Custom Field3

Assign
Close


Activation by activation code

With an Activation Card on PC Activator

Alternatively, use the helper application “PC Activator” to facilitate activation process.

1. Run PC Activator.
2. Enter Domain Admin’s credential and Activation code.
3. From the HMI list, select the one to be activated. The HW key will be loaded to the display field.
4. Depending on the HMI’s current activation status, the button below will show “Activate” or “Already activated”.
5. For ones that shows “Activate”, click on the button to complete activation.

Note: Support for PC activator varies among different model and OS versions.



EasyAccess20

Domain: Test

Username: admin

Password:

Activation code: 1234 - 5678 - ABCD - EFGH

HW Key: 7CZ7W7RD-WRDI-5AMZ-3YYB-E3IK-43HF75UT

Activate

HMI List

HMI Name	Type	Private IP
<input type="radio"/> Default HMI	eMT Series	192.168.1.17
<input checked="" type="radio"/> Default HMI	MT8100IE	192.168.1.18
<input type="radio"/> Default HMI	MT8121IE	192.168.1.38
<input type="radio"/> cMT-69A0	cMT-SVR	192.168.1.39

Default HMI has been checked

[Log History >](#)

PC Activator

By Hardware key through dealer

1. Provide the Hardware key to your dealer for assistance.

6. Add an HMI to a Domain

An HMI must belong to a domain to use EasyAccess 2.0 service.

When an HMI is activated by activation card, it is automatically added to that domain in which it is activated. However, when an activated HMI does not currently belong to any domain, once it goes online, it will obtain a set of Session ID/Password, which can be used to add the HMI to a domain.

EasyAccess 2.0 service requires that each HMI belong to only one domain. Therefore, once an HMI is added to one domain, it cannot be added to another one. Another Domain Admin will not be able to add that HMI even with the same Session ID/Password. For an HMI to be transferred to another domain, it needs to be removed from its current domain, and then it can be added to another domain with its new Session ID/Password.

How to find Session ID/Password?

Session ID/Password are generated uniquely for the HMI by the EasyAccess 2.0 service, the HMI must go online in order to receive this piece of information.

1. First, create and download an EasyBuilder program that displays Session ID/Password (system registers [LW-10821] to [LW-10827]), and allows setting LW-10820, the connection control register.

The above setup has been made available in a demo project and the template files.

2. Let HMI go online by setting [LW-10820] to ON.
3. Once successfully connected, HMI will display the Session ID/Password.

Review Chapter 8, [Configure EasyBuilder Pro Project](#) for more information.


EasyAccess 2.0

Bypasses firewall restriction and allows you to remotely control any PLCs via the Internet



State : **Online**

Error code : **Success**



Session ID : **879628085**

(-1: Error, 0: Already added in a domain, other: Ready to join)

Password : **4231**

[Demo Project](#) showing Session ID/Password

Add to domain by Session ID/Password

In domain page, under the “Devices” tab, click “Add HMI”, and then enter the Session ID/ Password and notes if needed.

+ Add HMI Weintek_FAE

Action type ⌵ Activate by session id/password

Session ID*

Password*

Custom Field1

Custom Field2

Custom Field3

Assign Close


Add to Domain by Session ID/Password

7. Manage the Domain

Go to <https://account.ihmi.net> to access the domain management system

Domain Creation

Anyone can create a new domain for free. A valid e-mail address is required.



The screenshot shows a web form titled "Create Domain" with a back arrow icon. The form contains the following fields and instructions:


- New Domain Name:** A text input field with the placeholder "Domain name". Below it, a note reads: "P.S. Register a domain admin name. The domain admin name is used as the account name. (Allow alphanumeric characters and underscores, case-insensitive)".
- Login Password:** A text input field with the placeholder "Login Password".
- Confirm Password:** A text input field with the placeholder "Confirm Password".
- Name:** Two text input fields labeled "First Name" and "Last Name".
- Email:** A text input field with the placeholder "Email". Below it, a note reads: "P.S. We'll send a confirmation email to this address once you click 'Register'".
- Continents / Regions:** A dropdown menu with "Africa" selected.
- Country:** A dropdown menu with "Algeria" selected.
- Company Name:** A text input field with the placeholder "Company Name".

A blue "Register" button is located at the bottom right of the form.

Create a Domain







User Management

The User list displays all users and their information in the Domain. It shows whether a user is associated with any HMI and if the user belongs to any HMI group. In this page, the Admin can carry out user management actions: Add User, Edit User, Delete User, or Copy User here. For domains with a large number of users, search tool is also available.



List of Users

Icon	Function
	<p>The Admin can create a new user ID in this window by providing an email address. Password information will be sent along with a confirmation email to the address provided. The new user must confirm registration by following the link in the mail to complete registration.</p>
	<p>The Admin can edit the HMI and HMI Group association for the selected user.</p>

Icon	Function
	<p>HMI/HMI Group » HMI Edit the selceted user’s association with HMIs.</p> <p>HMI/HMI Group » Group Add/Remove the selected user to/from HMI Groups.</p>  <p style="text-align: center;"><i>Adding a user to HMI groups</i></p> <p>Account Setting View infomration about this user account, and edit description and email information.</p>
 Delete User	Delete the selected user from this domain.
 Copy User	Create a user with the same HMI/HMI Group association.
<input type="text" value="Search..."/>	Search for a user by name
 user_name_ps 	A user whose name has a  mark beside indicates that the user is not assigned to any HMI.




Device Management

The HMI list shows all HMIs registered in the current domain, and the HMI Group list shows all groups currently existing in this domain. The first column can sort the HMI by name, while the other columns can be set to show the following information: Private IP, Public IP, Activation Date, or Custom Field.

HMI Name & Type	Private IP	Column2	Column3
• Demo-2 Type: eMT3070A	192.168.1.88		
• Default HMI Type: eMT3070A	192.168.1.33		
• Default HMI Type: MTB100IE	192.168.1.68		
• nicolas Type: eMT3070A	192.168.1.44		
• Default HMI Type: MTB050IE	192.168.5.23		
• Default HMI Type: eMT3070	192.168.1.144		
• cMT-6559 Type: cMT-SVR	192.168.1.161		
• Default HMI Type: eMT3070B	192.168.1.45		
• cMT-4820 Type: cMT-SVR	192.168.1.52		
• user_manual Type: MTB100IE	192.168.1.238		
• MTB100IE_Larry Type: MTB100IE	192.168.1.36		

HMI List

HMI Icon	Function
	<p>Add a new HMI to the domain.</p> <p>Action type » Using activation card</p> <p>Activate the HMI and add it to the current domain. Hardware key and activation code are required.</p> <p>Action type » activate by session id/password</p> <p>Add the HMI to the current domain by Session ID/Password. Session ID/Password is required.</p>
	<p>Edit the selected HMI</p> <p>User/HMI Group tab » User</p> <p>Edit user association with the selected HMI.</p> <p>User/HMI Group tab » HMI Group</p> <p>Add/Remove the selected HMI from the HMI groups.</p> <p>Activation Information</p> <p>View Hardware key and other information about this HMI.</p>
	<p>Delete the selected HMI from this domain. Once deleted, the HMI can be added to another domain with a new session id/password.</p>
	<p>Search for HMI by name. Enabling filter function will show only assigned / unassigned or all HMI.</p>

HMI Group Icon	Function
	Create a new HMI group.
	<p>Edit the selected HMI group</p> <p>HMI/User tab » HMI</p> <p>Add/Remove HMI from the selected group.</p> <p>HMI/User tab » User</p> <p>Edit user association with the selected group.</p> <p>General Setting</p> <p>View information about this HMI group.</p>
	Delete the selected HMI group.

Note: once an HMI is deleted from current domain, it can then be added to another domain. To add it back again, you will need the session id/password.

8. Configure EasyBuilder Pro Project


EasyBuilder Pro System Tags

A number of system tags are added to EasyBuilder Pro for exclusive use of EasyAccess 2.0.

System Tag	Function
LW-10820 (16bit)	Connect/Disconnect EasyAccess 2.0
	<i>0: Disconnect</i> <i>1: Connect</i>
LW-10828 (16bit)	EasyAccess 2.0 Online Status
	<i>0: Disable</i>
	<i>1: Offline</i>
	<i>2: Online</i>
	<i>3: Occupied</i>
LW-10829 (16bit)	Error code provides information about error status while the HMI is going online on EasyAccess 2.0.
	<i>0: Success.</i> <i>(Connection successful)</i>
	<i>1: Not activated.</i> <i>(EasyAccess 2.0 function is not activated on the HMI)</i>
	<i>2: Log-in timeout</i> <i>(Outbound connection is broken or the server is down)</i>
	<i>3: Certificate expired</i> <i>(License Key has expired. Please check with distributor.)</i>
	<i>4: HMI client not ready</i> <i>(Open and close client too frequently)</i>
	<i>5: HMI client will update</i> <i>(Update is downloaded and ready)</i>
<i>6: HMI client does not exist</i> <i>(Client program does not exist in HMI memory)</i>	
LW-10821 (5words, ASCII)	Session ID. This is used to add an HMI to a Domain.

LW-10826 Session Password. This is used to add an HMI to a Domain
(2words, ASCII)

Note: Demo pages using these system registers have been added to the template file in EasyBuilder Pro. Look for them when opening a new file to save time in your project design. Refer to Appendix for an example.



EasyAccess Page in the Template File

9. Connect the HMI to EasyAccess 2.0 Servers

With an activated HMI, go through the following step to connect to the EasyAccess 2.0. Ensure that this practice is done in the project in order to use EasyAccess 2.0.

1. Configure the EasyBuilder Pro project. In the EasyBuilder project, the user should be able to write to LW-10820.
2. Write "1" to LW-10820 to go online. HMI's EasyAccess 2.0 status should be "Online". Session id/password will be displayed accordingly, depending on whether the HMI has been added to a domain.

10. EasyAccess 2.0 PC client Program

EasyAccess 2.0 is provided as a standalone program that can be installed on the PC. It can be used independent of the EasyBuilder software suite.

Download the software from Weintek's website at:


<http://www.weintek.com/globalw/Software/EasyAccess.aspx>

Installing adaptors

During the first program run, the software will detect whether necessary adaptors are present. If not, they will be installed automatically.

Log in

Domain name, Domain username and password are required for login.




Login to EasyAccess 2.0

Main screen

Once successfully logged in, the main screen will show all HMIs for the user and their online states. HMIs that are online will have a connect button and a setting button. There is no limit on the number of HMIs that can be simultaneously connected from

the program. However, once an HMI is connected by a user, it goes into “occupied” state and cannot be connected by another user before the first connection has been terminated.




EasyAccess 2.0 Main Screen

Functions of icons on Main screen:

Icon	Function
Peter	Logged in user name
user	HMI search filter
	Tile view/ List view
	Settings
	Logout of current user
	Displays connection and gui logs.

Settings


Tab	Description
General » Network traffic	Enable/Disable traffic display under the HMI.

Information	Software version
Language	Select the language Languages available: English, French, Italian, Spanish, Russian, Simplified Chinese, Traditional Chinese, Korean, German.
Path » Executable	Select executable (*.exe) path for VNC viewer, HMI Viewer, and cMT Viewer, used to launch the viewers when connections are established.  <p>VNC executable path Location of the .exe executable of the VNC viewer. VNC viewer must be installed separately.</p> <p>HMI Viewer path Location of the GUI (gui_e30.exe).</p> <p>cMT Viewer path Location of the cMT Viewer, for use with cMT-SVR.</p>

Note: Please try to keep GUI updated as it is the necessary executable for running the HMI Viewer. A copy of GUI and cMT Viewer which was most current as of the date of EasyAccess 2.0 release is included in the installation. An update of GUI may be required when programming environment of the HMI was updated; in this case, find it in the latest version of EasyBuilder Pro.


HMI States and Access Setting

HMI can be in one of the states: Offline, Online, Connected, Occupied.



The usage or meaning of each icon:

Icon	Function
	HMI name
	Virtual IP address. Click to copy the IP address to clipboard.
	Set up pass-through IP address
	Connect to the HMI
	Disconnect from the HMI
	Access the HMI with VNC viewer (installed separately).
	Access the HMI with HMI Viewer
	Enter access setting of the HMI, which allows from using of VNC Viewer or HMI Viewer. To use VNC Viewer, set executable path in Settings page. To use HMI Viewer, set executable path in Settings page. Also, set how project upload and history should be handled.



Connection Log

Clicking on the LOG icon brings out the detail connection logs with the VPN, Authentication, and UAC server. The GUI tab shows information relevant to the use of HMI Viewer. In addition to viewing them here, it is also possible to save the logs as a file.

Note: GUI is the necessary component for running the HMI Viewer

Activity info

Save log

TYPE	TIME	CONTENT
ALL	VPN	Authentication
UAC	GUI	
TYPE	TIME	CONTENT
	2015-03-25 16:35:30 550	user_manual Traffic Usage: 5024 KB
	2015-03-25 16:35:30 277	user_manual EasyAccess version: 2.2.0
	2015-03-25 16:35:30 225	user_manual change state to online
	2015-03-25 16:31:18 099	user_manual Traffic Usage: 26 KB
	2015-03-25 16:31:15 717	weintek-openvpn 54.65.172.205
	2015-03-25 16:31:15 651	weintek-p2p vpn host: 54.65.172.205
	2015-03-25 16:31:15 566	user_manual change state to in_use
	2015-03-25 16:31:14 527	user_manual EasyAccess version: 2.2.0
	2015-03-25 16:31:14 465	user_manual change state to online
	2015-03-25 16:31:01 313	user_manual change state to offline
	2015-03-25 16:27:07 838	user_manual EasyAccess version: 2.2.0
	2015-03-25 16:27:06 980	user_manual EasyAccess version: 2.2.0
	2015-03-25 16:27:06 980	user_manual Traffic Usage: 26 KB
	2015-03-25 16:27:06 944	user_manual change state to online
	2015-03-25 16:27:05 905	choose no. 0 vpn server: TAP vpn server
	2015-03-25 16:27:02 320	Login : Weintek FAE.Peter

Connection Logs

Usage Display

The HMI's total data usage to date for the current month will be displayed.

The image shows a usage display widget for a user named 'user_manual'. It includes a monitor icon, the IP address '10.7.0.6', and the status 'Pass-through'. At the bottom, a teal bar displays a pulse icon and the text '7.40MB'. There are also control icons for refresh, settings, and a close button.

Usage Display

11. Connect to the HMI by EasyAccess 2.0 on PC

Step-by-step for establishing EasyAccess 2.0 connection.



1. Launch EasyAccess 2.0.exe.



2. Enter Domain name, Domain user's username and password, and then click [Login].



3. Once logged in, the program will list user's HMIs and their statuses.




4. Click on connect button to establish connection to an online HMI. Once connected, the virtual IP address will be displayed. It is now possible to connect directly to the HMI by net services such as VNC, HMI Viewer, or FTP.



5. When finished, click on disconnect button to terminate the connection.

12. Pass-through with EasyAccess 2.0


Remote Pass-through is made possible and simple with EasyAccess 2.0. Similar to the traditional way of local pass-through, it is done with a helper program in Utility Manager. Simply enter the virtual IP address obtained in EasyAccess 2.0 in the pass-through program, as shown in the following figure. The remaining steps are the same as local pass-through. In doing remote pass-through, additional port settings are not required.



Pass-through setting in Utility Manager


13. Pass-through Connect to a remote PLC on the HMI's network (Ethernet pass-through)

EasyAccess 2.0 not only makes possible direct connection to a Weintek HMI, but also provides pass-through function that enables the user to connect to the PLC on the remote HMI's network. Consider an EasyAccess network as shown below where a PLC is within the same LAN network as the HMI. Here, the PC, by first establishing EasyAccess 2.0 connection to the HMI, may use the HMI as the relay and connect to the PLC as well.



How to setup pass-through to PLC?


1. On the list of HMI, click on the “Pass-through” icon which appears below the IP address when connection in active.



2. Enter the IP address of the target PLC.



3. Once connected, the IP address of the PLC will be shown. The user may now launch the PLC program.



If the remote PLC and the local computer have the same private IP address range, a warning will appear, indicating that subsequent connection to the PLC's IP address will be directed to the remote device instead of the local device if there is any.




This will override connection to 192.168.1.20 to remote device. You see this message because the IP address (192.168.1.20) is in your local network (192.168.1.0/255.255.255.0).

14. Proxy Server

A proxy server acts as an intermediary between clients and servers. In some network infrastructure, especially that of a large scale, proxy servers are used to ensure security, administrative control, and efficiency of the network. To establish connection with EasyAccess 2.0 through proxy, however, requires additional settings in EasyAccess 2.0 client program and/or the HMI.

Proxy settings at PC's EasyAccess 2.0 client side and HMI side are similar. On PC, proxy setting window can be called from the setting button of the login screen. On HMI it is found in the [EasyAccess 2 tab] of system settings. Enter the proxy type, host address, port number and login credentials obtained from the network administrator.



Proxy Settings

Proxy related system tags

The following table lists the system tags reserved for EasyAccess 2.0 proxy settings:

LW-11170 (16bit)	Proxy Disable/Enable (0: disable, 1: enable)
LW-11171 (16bit)	Proxy Type (0: HTTP, 1: SOCKSv4, 2: SOCKSv5)
LW-11172 (16bit)	Proxy Server IP0
LW-11173 (16bit)	Proxy Server IP1
LW-11174 (16bit)	Proxy Server IP2
LW-11175 (16bit)	Proxy Server IP3
LW-11176 (16bit)	Proxy Server Port
LW-11177 (16bit)	Proxy authentication (0: disable, 1: enable)
LW-11178 (16 words)	Proxy username
LW-11194 (16 words)	Proxy password



15. EasyAccess 2.0 on Android

EasyAccess 2.0 is available for Android devices. With EasyAccess 2.0, users can easily use VNC or cMT Viewer to access remote HMI. Even though the UI and available functionalities on an Android device maybe slightly different from PC, the connection steps are as simple and straightforward.

EasyAccess 2.0 on Android requires Android version 4.1.2 or later.

App Download

In addition to the main app EasyAccess 2.0, a helper OpenVPN Connector app is required. Please download the apps from the App store and install the apps, both of which are free.

Icon	App Name	App Provider
	EasyAccess 2.0	Weintek Labs., Inc,
	EasyAccess 2.0 OVPN Connector	Weintek Labs., Inc.

Step-by-step connection guide



1. Launch EasyAccess 2.0 app.

LOGIN

2. Enter Domain name, Domain user's username and password, and then click [Login].




3. Once logged in, the app will list user's HMIs and their statuses.



4. Click on the connect button to establish connection to an online HMI."



5. Once connected, the virtual IP address will be displayed. The top status bar will also display a VPN icon. It is now possible to connect directly to the remote HMI by VNC or cMT Viewer.



6. When finished, return to EasyAccess 2.0 app and click on the disconnect button to terminate the connection.



16. EasyAccess 2.0 on iPad

EasyAccess 2.0 is available on iOS for iPad. With EasyAccess 2.0, users can easily use VNC or cMT Viewer to access remote HMI. However, due to software restrictions, connection steps are slightly different from those on PC.

EasyAccess 2.0 on iPad requires iOS version 7.0 or later.

Download from the app store

In addition to the main app EasyAccess 2.0, OpenVPN Connect app is required. Please download the apps from the App store and install the apps, both of which are free.

Icon	App Name	App Provider
	EasyAccess 2.0	Weintek Labs., Inc.
	OpenVPN Connect	OpenVPN Technologies

Step-by-step connection guide



1. Launch EasyAccess 2.0 app




2. Enter Domain name, Domain user's username and password, and then click [Login].




3. Once logged in, the program will list user's HMIs and their statuses.




4. Click on connect button to establish connection to an online HMI. Dialogue will show with action buttons. Click "Open in OpenVPN."



- In OpenVPN app, add the login profile, and toggle the connection button to initiate connection.



- Once connected, return to EasyAccess 2.0 app and the virtual IP address will be displayed. The top status bar will also display a VPN icon. It is now possible to connect directly to the remote HMI by VNC or cMT Viewer.



7. When finished, click on disconnect button to terminate the connection.

17. Frequently Asked Questions

Q: My HMI is broken down and I am sending back my machine for repair. Can I use my old EasyAccess 2.0 license on my replacement machine?

A: Please contact us by service request on our [website](#).

Q: I cannot activate while using PC Activator. HW Key text field is showing “Not Supported.”

A: Please check the HMI’s OS and refer to [Ch.18](#) for the list of PC Activator - supported model and OS version.

Q: I do not see the EasyAccess 2 tab.

A: Please check the HMI’s OS and refer to [Ch.18](#) for the list of EasyAccess 2.0 - supported model and OS version.

Q: On the EasyAccess 2 tab, it says “connect to the server fails?” in red.

A: The HMI cannot connect to the internet. Please make sure Internet access is available to the HMI. Check the IP address, Gateway, and DNS address settings.

If the HMI has an OS version prior to 20140814, you might see this message too. This indicates that security certificate on the HMI has expired and cannot work with the EasyAccess 2.0 server. In order to use EasyAccess 2.0 again, you must update the certificate manually. The update procedure is as follows:


1. With the latest EasyBuilder Pro, download the EasyAccess 2.0 [Demo project](#) (or any project which allows LW-10820 to be set to 1) to the HMI. When downloading, make sure EasyAccess 2.0 checkbox is ticked.
2. On the HMI, click the “connect” button (or set LW-10820 to 1); security certificate update will begin.
3. Check the activation status again in the system information page.

Q: I notice that VPN IP address can change between sessions. Is it normal?

A: Yes, it is perfectly normal. EasyAccess 2.0 connections are established on demand, so VPN IP address may change. Also, on PC or Android device, IP address starting with 10.8 denotes a connection made in point-to-point (P2P) mode as opposed to VPN mode. In general, P2P mode allows higher data rate than VPN does. The program will determine the mode to use based on current network conditions.

Q: When I try to connect to EasyAccess 2.0 by setting LW-10820, nothing happens.

A: Please make sure that EasyAccess client program is in the HMI. It should have been downloaded to the HMI during project download. If not, check the version of EasyBuilder Pro used and whether `easy_access_client.e30` is in the firmware folder.



Q: I've just updated my OS to the latest release, but my activation disappeared. Do I have to re-activate?

A: In the EasyAccess 2 tab, click on the [Refresh] button. EasyAccess 2.0 will be re-activated if the same HMI was previously activated.

Q: I'm using Windows 8 and the SmartScreen warns that running the software may put my PC at risk.

A: If you obtained our software from the official channel, either directly from us or from a trusted dealer, you can rest assured that the software is safe. Click on "More info", and then "Run Anyway" to continue.

18. References

System Restrictions

Restriction	Description
Data Rate and Usage Limit	Data rate at 100 kB/s for the first 1GB and 5 kB/s after. Usage count restarts on the 1st day of each calendar month.
# of Domain an HMI can be registered in	1
# of users an HMI can be connected by at a time	1. See "Occupied" status in Appendix.
# of HMI a user can connect to at a time	Unrestricted
Service Port	HTTPS port (443)
Ethernet-Ethernet Pass-through	1 IP

Model and OS Support

HMI OS versions that support **EasyAccess 2.0**

Model	OS version or later
eMT3070A	20140624
eMT3070B	All versions
eMT3105, eMT3120, eMT3150 *	20140701
MT8070iE, MT8100iE	20140626
MT8050iE, MT8071iE, MT8101iE	20140624
MT8090XE, MT8091XE	All versions
MT8121XE, MT8150XE	20140624
mTV-100	20140815
cMT-SVR	20140715

* EasyAccess 2.0 is not available for eMT3105, eMT3120 and eMT3150 shipped prior to June, 2012.

HMI OS that supports **PC Activator** (current as of July 2015)

Model	OS version or later
eMT3070A	TBA
eMT3070B	20150603
eMT3105,eMT3120, eMT3150	TBA
MT8070iE, MT8100iE	20150508
MT8050iE, MT8071iE, MT8101iE	20150527
MT8090XE, MT8091XE	20150603
MT8121XE, MT8150XE	20150603
mTV-100	20150508
cMT-SVR	TBA

19. Appendix

Terminology

(Online Status) Online:

When an HMI goes on-line, it sends keep-alive information to keep-alive server and lets all EasyAccess 2.0 clients know it is ready for connection. There is still no connection in this state unless one EasyAccess 2.0 client connects to it.


(Online Status) Occupied:

When an EasyAccess 2.0 client connects to the HMI, then the HMI is **occupied** and no other EasyAccess 2.0 client can connect to it until it is disconnected.


Example for preparing EasyAccess 2.0 page

Here are the steps for preparing EasyAccess 2.0 page from the new template file in EasyBuilder Pro.

1. Create a new project using templates, and you can see window #76 as below:



2. In window #10, add a [Function Key] object to popup window #76.



3. Download the project to HMI.
4. On HMI, click the [Function Key] object which was just added.
5. Click “Start” button.

If the network setting of the HMI is correct, the state will be online like the following:

